OF THE SUPPLY

MISSISSIPPI STATE DEPARTMENT OF HEALTH BUREAU OF PUBLIC WATER SUPPLY 20 CCR CERTIFICATION 2014 JUN 20 AN 8: 50

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

Advertisement in local paper (attach On water bills (attach copy of bill) Email message (MUST Email the mother	•
Date(s) customers were informed: 5/15/14,	/ / /
CCR was distributed by U.S. Postal Service or o methods used	other direct delivery. Must specify other direct delivery
Date Mailed/Distributed:	
CCR was distributed by Email (MUST Email MSDI- As a URL (Provide URL	
CCR was published in local newspaper. (Attach copy	of published CCR or proof of publication)
Name of Newspaper: The Part Hilso	n Reville
Date Published: 5/15/2014	
CCR was posted in public places. (Attach list of local	Date Posted: / /
CCR was posted on a publicly accessible internet site	e at the following address (<u>DIRECT URL REQUIRED</u>):
CERTIFICATION I hereby certify that the 2013 Consumer Confidence Reppublic water system in the form and manner identified the SDWA. I further certify that the information include the water quality monitoring data provided to the public President Bureau of Public Water Supply. Name/Title (President Mayor, Owner, etc.)	port (CCR) has been distributed to the customers of this above and that I used distribution methods allowed by ed in this CCR is true and correct and is consistent with ublic water system officials by the Mississippi State L-17-14 Date

Deliver or send via U.S. Postal Service: Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215

> May be faxed to: (601)576-7800

May be emailed to: Melanie. Yanklowski@msdh.state.ms.us

2013 Annual Drinking Water Quality Report CS&I Water Association PWS#: 0110002 May 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the CS&I Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Robert St. John at 601.437.4304. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 6:00 PM at 3148 Karnac Ferry Rd., Port Gibson, MS.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Contaminant	Vialatio		e ie	~~~		EST RES		Total					
	YAN	Coll	acted	Lave! Defecte		nge of Detects of # of Samples Exceeding MCL/ACL	Unit Measure ment	MC	ЖG	MC	L	Likely Source of Contameration	
Radioacti	ve Cont	amin:	ants				<u> </u>	<u> </u>		٠			
5. Gross Alpha	N	2012		7.31	'T3	96 - 7.31	pCid.	i o	······	18			
7. Uranium 1	N	2012		.293		278 - 293	ug/L						
Inorganic	Cantar			·			ugrL	L <u>.</u>		30,	1	Espaion of natural deposits	
and Game	Commi	is a superage	13										
10, Harlum	N.	2011*		.016	T No.	Range	pioris			ı			
					1		Pauria	2			2	Discharge of drifting wastes, discharge from metal refinence	
16. Fluoride	110	N 2011-		1.02								Erosion of natural deposits, we additive which appropries since	
		-		tiqu <u>a</u>	.Mor	- 1.02	apm	4		4			
17 Lead	N	2009/1										teeth, discharge from fedilizer and aluminum factories	
	1"	40061	1		a		ppts		O ALWIE		15	Cormsion of finuseficid plumbil systems, provion of natural	
Disinfectio	- D. D.										ىل	depoeis	
81 HAAS		2012*			سنسب								
	, n	ZUIZ	30	- 11	io Rang	le ppo	3 19 4	a		60	By	By-Product of drinking water	
i2. FTHM Total rihalomethanasT	N	2012*	70	٨	o Ranç	e ppb	1	0	0 69		disensation Sy-product of drinking water chlorination		
Hiorine	N :	2019	- 9.		90-13	mg/l		Q MD		RL = 4			
Thursday (No. 1)	Angle Control of Control	200,000	<u> </u>						DAM	ru_ ~ 4	VVB	nter additive used to comfol	

to one minute in 2,000 years, or a single penny in \$10,000,000.

* Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected; however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The CS & I Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2013 Annual Drinking Water Quality Report
CS&I Water Association PWS#: 0110002
May 2014
We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you
every day. Our constant goal is to provide you with a safe and dependable supply of
dirinking water. We want you to understand the efforts we make to continually improve
the water treatment process and protect our water resources. We are committed to
ensuring the quality of your water. Our water source is from wells drawing from the
Cataloula Aquifer. Catahoula Aquifer:

The source water assessment has been completed for our public water system to

XNF

ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the CS&I Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Robert St. John at 601.437.4304. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 60.09 M at 3148 Karnae Ferry Rd., Port Gibson, MS.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, racioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from ewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as viruses and bacteria, that may come from ewage treatment plants, septic systems, agricultural investock operations, and wildlife; inorganic contaminants, such as a significant processes and period period period period period period period period period of promise the second of industrial, or domestic wastewater di

tions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as a feasible using the best available treatment technology.

Maximum Contaminant Level (God (MCLG) - The "God ("MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfactant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant.

tant allowed in drinking water. There is convincing evidence that addition of a disin-fectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking

maximum regular Distinction Level took (MADDA). The level of a dimining water disinfectant below which there is no known or expected risk of health MRDLGs do not reflect the benefits of the use of disinfectants to control microbial

ntaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corsponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter = one part per billion corresponds

2014 J.T. 20 AN 8: 50

PUBLISHER'S OATH

State of Mississippi

State of Mississippi
Claiborne County, Mississippi
Personally appeared before the undersigned NOTARY PUBLIC of said count,
IEMMA R CRISLER, Publisher of the Port Gibson Reveille, a weekly newspaper,
printed and published in the town of Port Gibson, in said county and state, who,
being duly sworn deposes and says that said newspaper has been established for
more than twelve months next prior to first publication of a notice, of which, the wit:

copy, has been made in said paper cons-	ecutively, to
On the 15thday of May	. 20
On the day of	. 20
On the day of	. 20
On the day of	20
Publisher	, 20
1 Transfer	

TEST RESULTS